

**ADDENDUM NO. 1**  
**AIP No. 3-46-0048-052-2019**  
**TERMINAL REHABILITATION PHASE II**  
**PASSENGER TERMINAL CHILLER REPLACEMENT**  
**RAPID CITY REGIONAL AIRPORT**  
**RAPID CITY, SOUTH DAKOTA**  
**BID OPENING: JANUARY 18, 2019 @ 11:00 AM LOCAL TIME**

The following addendum shall be acknowledged as having been received and marked as such on the outside of the sealed envelope containing the bid and Page 1 of the Bid Form.

The following additions and/or corrections shall be made to and become a part of the plan and/or specifications.

1. **PRODUCT APPROVALS.** The manufacturers and products, which are listed in the following texts, are approved for bidding. Final acceptance is contingent upon receipt and approval of final shop drawings. Manufacturer shall conform to all warranties, performances, size, etc., as the item specified. The burden of proof of the merit of the proposed substitution is upon the proposer. Those items not specifically listed by addendum shall not be approved for bidding.

<u>Section</u>	<u>Description</u>	<u>Manufacturer</u>
23 82 39	Unit Heaters	Modine Manufacturing Company

2. **SECTION 23 21 13 HYDRONIC PIPING.** Add the following new section – Specification 23 21 13 Part 2 Products 2.1 Acceptable Manufactures as follows:

D. Grooved Systems: Victaulic, Anvil Gruvlok

3. **SECTION 23 21 13 HYDRONIC PIPING.** Add the following new section – Specification 23 21 13 Part 2 Products 2.2 Chilled Water Piping A.2.b Fittings as follows:

- 4) Grooved
  - a) 2 inch thru 12 inch couplings
    - i. Victaulic QuickVic Rigid Coupling Style 107, EPDM gaskets
    - ii. Victaulic QuickVic Flexible Coupling Style 177, EPDM gaskets
  - b) 14 inch and larger couplings
    - i. Victaulic Rigid Coupling Style W07, EPDM gaskets
    - ii. Victaulic Flexible Coupling Style W77, EPDM gaskets
  - c) Flange adapters
    - i. ANSI Class 125/150: Victaulic Style 741/W741
    - ii. ANSI Class 300: Victaulic Style 743

**4. SECTION 23 21 13 HYDRONIC PIPING.** Add the following new section – Specification 23 21 13 Part 2 Products 2.3 Condenser Water Piping A.2.b Fittings as follows:

- 4) Grooved
  - a) 2 inch thru 12 inch couplings
    - i. Victaulic QuickVic Rigid Coupling Style 107, EPDM gaskets
    - ii. Victaulic QuickVic Flexible Coupling Style 177, EPDM gaskets
  - b) 14 inch and larger couplings
    - i. Victaulic Rigid Coupling Style W07, EPDM gaskets
    - ii. Victaulic Flexible Coupling Style W77, EPDM gaskets
  - c) Flange adapters
    - i. ANSI Class 125/150: Victaulic Style 741/W741
    - ii. ANSI Class 300: Victaulic Style 743

This document was originally issued and sealed by Rodney A. Senn, Registration Number 6136 on January 7, 2019 and the original documents are stored at KLJ, Rapid City, SD. This media should not be considered a certified document.

---

Rodney A Senn, PE  
Kadmas, Lee & Jackson, Inc.

END OF ADDENDUM NO. 1